

# Type test Certificate of

## **Trench Italia S.r.l.**

Cairo Montenotte, Italy

has successfully passed the type test sequence on a oil-immersed

## **capacitor voltage transformer, outdoor type**

Type: TCVT 420

Rating: 420 kV – 630/1050/1425 kV – 700 VA - 1,2-cont./1,57-30 s – 50 Hz

The test object passed the required clauses of


## **IEC 61869-5**

The test results are recorded in Certificate No.

## **TIC 1062-12**

This Certificate is issued on 27 February 2013

KEMA Nederland B.V.



S.A.M. Verhoeven

Director Testing, Inspections & Certification The Netherlands

